Hinweis zur Verkabelung /
Notice on wiring

DE

Der **Kabelabgang aus dem Gerät** hat nach unten zu erfolgen, damit keine Feuchtigkeit über das Kabel in das Gerät eindringen kann.

Bei **kurzen Kabelabgängen** ist das Kabelende versiegelt, um hier Abhilfe zu schaffen.

Bei **langen Kabelabgängen** ist dafür zu sorgen, dass das offene Kabelende nicht in einer feuchten Umgebung liegt oder dass das offene Kabelende unterhalb des Gerätes liegt.

Die **Kabeltülle am Gerät** darf nicht auf Bewegungs- oder Zugbelastung beansprucht werden. Dies führt zu einer Undichtigkeit.

Der **Mindestbiegeradius** ist zu beachten:

fest verlegt	Kabeldurchmesser ≤ 12 mm	3 x D
	Kabeldurchmesser > 12 mm	4 x D
gelegentlich bewegt	Kabeldurchmesser ≤ 12 mm	4 x D
	Kabeldurchmesser > 12 mm	5 x D

EN

The **cable exit from the unit** must be downwards so that no moisture can enter the unit via the cable.

For **short cable outlets**, the cable end is closed to prevent this.

For **long cable outlets**, make sure that the open cable end is not in a damp environment or that the open cable end is below the unit.

The **cable gland on the unit** must not be exposed to any movements or tensile loads. This will lead to leaks.

The **minimum bending radius** must be observed:

fixed	cable diameter ≤ 12 mm	3 x D
	cable diameter > 12 mm	4 x D
occasionally moved	cable diameter ≤ 12 mm	4 x D
	cable diameter > 12 mm	5 x D